

AMENDMENT TO BILL NO. 21-003  
(Page and line references are to Bill as Introduced)

Introduced by: Council Member Shrodes

Legislative Session Day: 21-016  
Date: May 18, 2021

**Amendment No. 2**

On page 1, in line 25, after “BOUNDARY.” insert “ALL UNDERGROUND STORAGE  
TANKS MUST USE TRIPLE-WALLED TANKS AND TRIPLE-WALLED PIPING FOR  
PRODUCT, VAPOR AND VENTS.”

**Amendment No. 2 to Bill No. 21-003**

**Introduced – LSD 21-016 Adopted - LSD \_\_\_\_\_**

**Place on Procedural**

**Layover \_\_\_\_\_ Rejected – LSD 21-016 (Due to lack of 2<sup>nd</sup>)**

**Tabled LSD \_\_\_\_\_ Withdrawn - LSD \_\_\_\_\_**